

Deemed-to-Satisfy Provisions
Table 3 WALL AND CEILINGS LINING MATERIALS (Material Groups permitted)

Class of Building	Fire-isolated exits and fire control rooms Wall/Ceiling	Public Corridor:		Specific Area:		Other areas Wall/Ceiling
		Wall	Ceiling	Wall	Ceiling	
Class 2 or 3 Excluding accomodation for the aged, people with disabilities, and children						
Unsprinklered	1	1, 2	1, 2	1, 2, 3	1, 2, 3	1, 2, 3
Sprinklered	1	1, 2, 3	1, 2, 3	1, 2, 3	1, 2, 3	1, 2, 3
Class 3 or 9a Accomodation for the aged, people with a disability, children and health-care buildings						
Unsprinklered	1	1	1	1, 2	1, 2	1, 2, 3
Sprinklered	1	1, 2	1, 2	1, 2, 3	1, 2, 3	1, 2, 3
Class 5, 6, 7, 8 or 9b schools						
Unsprinklered	1	1, 2	1, 2	1, 2, 3	1, 2	1, 2, 3
Sprinklered	1	1, 2, 3	1, 2, 3	1, 2, 3	1, 2, 3	1, 2, 3
Class 9b other than schools						
Unsprinklered	1	1	1	1, 2	1, 2	1, 2, 3
Sprinklered	1	1, 2	1, 2	1, 2, 3	1, 2, 3	1, 2, 3
Class 9c Sprinklered	1	1, 2	1, 2	1, 2, 3	1, 2, 3	1, 2, 3
For the purpose of this Table -						
1 "Sprinklered" means a building fitted with a sprinkler system complying with Specification E1.5 .						
2 "Specific areas" means within -						
(a) for Class 2 and 3 buildings, a sole-occupancy unit; and						
(b) for Class 5 buildings, open plan offices with a minimum floor dimension/floor to ceiling height ratio >5; and						
(c) for Class 6 buildings, shops or other building with a minimum floor dimension/floor to ceiling height ratio >5; and						
(d) for Class 9a <i>health-care buildings, patient care areas</i> ; and						
(e) for Class 9b theatres and halls, etc, an auditorium; and						
(f) for Class 9b <i>schools</i> , a classroom; and						
(g) for Class 9c buildings, <i>residents use areas</i>						

